

# Pick Park




Pick Park is a new medium sized neighborhood park that provides walkways, playground, picnic tables and dog waste bags. The main issues at this park are dog waste bags are too far from the accessible route and there are not enough accessible picnic tables. **Please Note:** When a **UD** is indicated, this is a Universal Design (**UD**) recommendation to enhance accessibility. The **UD** recommendation is not required to meet the minimum accessibility standards but it would be encouraged. If used in this report, the letters, **AFF** stand for above finished floor.


The report uses two different accessibility codes. The 2010 Americans with Disabilities Act Accessibility Guidelines (ADAAG) can be down loaded from the Access Board website. The website is [www.access-board.gov](http://www.access-board.gov). In addition, the Illinois Accessibility Code (IAC) was also used in this report. This code can be down loaded from the website, [www.cbd.state.il.us/IAC](http://www.cbd.state.il.us/IAC). The estimated costs for correction of access barriers are taken from the "Means ADA Compliance Pricing Guide 2nd Edition". Each estimated costs for corrective actions have been adjusted for inflation and regional costs to better reflect the 2024 expenses in the suburban Chicagoland area.

The Elmhurst Park District is part of a local government which requires compliance with Title II of the Americans with Disabilities Act (ADA). Changes to the Park District would allow for equal opportunity to participate in programs and activities, effective communication, and program accessibility. Access of programs and activities can be achieved by removal of physical barriers, modification of policies, practices and procedures that discriminate against a person with a disability and relocation to an accessibility facility. In existing facilities, the ADA does allow the relocation of a program from an inaccessible facility to an accessible facility until all access barriers have been removed. See 28 C.F.R. §35.150(a)(1);(b)(1) for additional information.

PLEASE NOTE: In existing facilities, the ADA does allow the relocation of a program from an inaccessible facility to an accessible facility until all access barriers have been removed. See 28 C.F.R. §35.150(a)(1);(b)(1) for additional information. ADAAG 206.2 requires that at least one accessible route be provided within the boundary of the site. The reports provide comments on all routes that when upgrades are made in the future modifications can be made to correct the access barrier or in some cases modify to the greatest extent possible.

Photo	Barrier	ADAAG/IAC	Solution	Priority	By Whom	Projected Cost	Projected Date	Action Taken
	The dog waste bags are too far away from the accessible route at 36 inches.	ADAAG 403.3	Relocate the dog waste bag dispenser to be on an accessible route or provide a new accessible route with a running slope no steeper than 5% and a cross slope no steeper than 2% and a minimum clear width of 36 inches.	4		\$ 185.00		

# Pick Park

Photo	Barrier	ADAAG/IAC	Solution	Priority	By Whom	Projected Cost	Projected Date	Action Taken
	<p>There are 3 picnic tables but only one is accessible.</p>	<p>IAC 245 &amp; 1011</p>	<p>At least 20% of picnic tables, but no less than two, be of an accessible design, connected to an accessible route. Provide picnic tables that have a clear floor space of 30 inches minimum by 48 inches minimum, a table top between 28 inches minimum of 34 inches maximum and a minimum 27 inches knee clearance. The knee clearance should go 17 inches to 25 inches under the top. Relocate or purchase one more accessible picnic table (\$1000/each) and locate it on an accessible surface.</p>	<p><b>2</b></p>		<p>\$ 1,000.00</p>		
<p><b>Estimated Total Cost for Accessibility Upgrades at Pick Park</b></p>						<p><b>\$ 1,185.00</b></p>		